Solid State Relays

New Models with 75-A and 90-A Output Currents Join the Previous Models with 5- to 40-A Output Currents.

- AC Output Relays with 75-A and 90-A output currents have been added to the G3NA Series. The standard versions of these models provide certification for international standards (-UTU).
- All models feature the same compact dimensions to provide a uniform mounting pitch.
- · Built-in varistor effectively absorbs external surges.
- Operation indicator enables monitoring operation.
- Protective cover for greater safety.
- Standard models certified by UL and CSA and -UTU models by VDE (TÜV) (TÜV-version not available for G3NA-410B, G3NA-420B, and G3NA-440B).

Model Number Structure

Model Number Legend

<u>G3NA-</u>____

1 234567

- 1. Basic Model Name
- G3NA: Solid State Relay
- 2. Load Power Supply Blank: AC output
- D: DC output
- 3. Rated Load Power Supply Voltage
 - 2: 200 VAC or 200 VDC
 - 4: 400 VAC

4. Rated Load Current

- 05: 5 A
- 10: 10 A
- 20: 20 A
- 40: 40 A
- 50: 50 A

- 5. Terminal Type
- B: Screw terminals
- 6. Zero Cross Function
 - Blank: Equipped with zero cross function (AC-output models only)
- 7. Certification
 - Blank: Standard models (certified by UL and CSA)
 - UTU: Certified by UL, CSA, and TÜV



(€¶)∰≙

Ordering Information

■ List of Models

Isolation	ation Zero cross Indicator Applicable output load Rated input voltag (See note 1.)		Rated input voltage	Model	
Phototriac	Yes	Yes	5 A at 24 to 240 VAC	5 to 24 VDC	G3NA-205B DC5-24
Photocoupler			(See note 2.)	100 to 120 VAC	G3NA-205B AC100-120
				200 to 240 VAC	G3NA-205B AC200-240
Phototriac			10 A at 24 to 240 VAC	5 to 24 VDC	G3NA-210B DC5-24
Photocoupler			(See note 2.)	100 to 120 VAC	G3NA-210B AC100-120
				200 to 240 VAC	G3NA-210B AC200-240
Phototriac			20 A at 24 to 240 VAC	5 to 24 VDC	G3NA-220B DC5-24
Photocoupler			(See note 2.)	100 to 120 VAC	G3NA-220B AC100-120
				200 to 240 VAC	G3NA-220B AC200-240
Phototriac			40 A at 24 to 240 VAC (See note 2.)	5 to 24 VDC	G3NA-240B DC5-24
Photocoupler				100 to 120 VAC	G3NA-240B AC100-120
				200 to 240 VAC	G3NA-240B AC200-240
Phototriac			(See note 2.) 90 A at 24 to 240 VAC	5 to 24 VDC	G3NA-275B-UTU DC5-24
Photocoupler				100 to 240 VAC	G3NA-275B-UTU AC100-240
Phototriac				5 to 24 VDC	G3NA-290B-UTU DC5-24
Photocoupler			(See note 2.)	100 to 240 VAC	G3NA-290B-UTU AC100-240
			10 A at 5 to 200 VDC	5 to 24 VDC	G3NA-D210B DC5-24
				100 to 240 VAC	G3NA-D210B AC100-240
	Yes		10 A at 200 to 480 VAC	5 to 24 VDC	G3NA-410B DC5-24
				100 to 240 VAC	G3NA-410B AC100-240
			20 A at 200 to 480 VAC	5 to 24 VDC	G3NA-420B DC5-24
				100 to 240 VAC	G3NA-420B AC100-240
			40 A at 200 to 480 VAC	5 to 24 VDC	G3NA-440B DC5-24
				100 to 240 VAC	G3NA-440B AC100-240
			75 A at 200 to 480 VAC	5 to 24 VDC	G3NA-475B-UTU DC5-24
				100 to 240 VAC	G3NA-475B-UTU AC100-240
			90 A at 200 to 480 VAC	5 to 24 VDC	G3NA-490B-UTU DC5-24
				100 to 240 VAC	G3NA-490B-UTU AC100-240

*The standard models are certified by UL and CSA. To order a TÜV-certified model, add "-UTU" to the model number.

Note: 1. The applicable output load depends on the ambient temperature. Refer to *Load Current vs. Ambient Temperature* in *Engineering Data*.
2. Loss time increases under 75 VAC. (Refer to page 15.) Confirm operation with the actual load.

■ Accessories (Order Separately) One-touch Mounting Plates

Model					
R99-12 FOR G3NA					

Heat Sinks

Slim Models Enabling DIN-track Mounting

Model	Applicable SSR					
Y92B-N50	G3NA-205B, G3NA-210B, G3NA-D210B, G3NA-410B, G3NA-210T(L)					
Y92B-N100	G3NA-220B, G3NA-420B, G3NA-220T(L)					
Y92B-N150	G3NA-240B, G3NA-440B					
Y92B-P250NF	G3NA-275B-UTU, G3NA-290B-UTU, G3NA-475B-UTU, G3NA-490B-UTU					

Mounting Bracket

Model	Applicable SSR
R99-11	G3NA-240B, G3NA-440B

Low-cost Models

Model	Applicable SSR
Y92B-A100	G3NA-205B, G3NA-210B, G3NA-D210B, G3NA-220B, G3NA-410B, G3NA-420B
Y92B-A150N	G3NA-240B, G3NA-440B
Y92B-A250	G3NA-440B

Specifications

■ Ratings

Input (at an Ambient Temperature of 25°C)

Model	Rated voltage Operating voltage			Voltage level			
			(See note 1.)	Must operate voltage	Must release voltage		
G3NA-2□□B	5 to 24 VDC	4 to 32 VDC	7 mA max. (See note 2.)	4 VDC max.	1 VDC min.		
	100 to 120 VAC	75 to 132 VAC	36 kΩ±20%	75 VAC max. (See note 3.)	20 VAC min. (See note 3.)		
	200 to 240 VAC	150 to 264 VAC	72 kΩ±20%	150 VAC max. (See note 3.)	40 VAC min. (See note 3.)		
G3NA-4□□B	5 to 24 VDC	4 to 32 VDC	5 mA max. (See note 2.)	4 VDC max.	1 VDC min.		
G3NA-D210B	100 to 240 VAC	75 to 264 VAC	72 kΩ±20%	75 VAC max.	20 VAC min.		
G3NA-275B-UTU G3NA-290B-UTU		4 to 32 VDC	15 mA max. (See note 2.)	4 VDC max.	1 VDC min.		
G3NA-475B-UTU G3NA-490B-UTU	100 to 240 VAC	75 to 264 VAC	72 kΩ±20%	75 VAC max.	20 VAC min.		

Note: 1. The input impedance is measured at the maximum value of the rated supply voltage (for example, with the model rated at 100 to 120 VAC, the input impedance is measured at 120 VAC).

2. With constant current input circuit system. The impedance for the G3NA-2□□B-UTU is 15 mA max.

3. Refer to Temperature Characteristics (for Must Operate Voltage and Must Release Voltage) in Engineering Data for further details.

<u>Output</u>

Model	Applicable load							
	Rated load voltage	Load voltage range	Load curren	Inrush current				
			With heat sink (See note 2.)	Without heat sink				
G3NA-205B	24 to 240 VAC	19 to 264 VAC	0.1 to 5 A (at 40°C)	0.1 to 3 A (at 40°C)	60 A (60 Hz, 1 cycle)			
G3NA-210B	Ī		0.1 to 10 A (at 40°C)	0.1 to 4 A (at 40°C)	150 A (60 Hz, 1 cycle)			
G3NA-410B	200 to 480 VAC	180 to 528 VAC	0.2 to 10 A (at 40°C)	0.2 to 4 A (at 40°C)	1			
G3NA-220B	24 to 240 VAC	19 to 264 VAC	0.1 to 20 A (at 40°C)	0.1 to 4 A (at 40°C)	220 A (60 Hz, 1 cycle)			
G3NA-420B	200 to 480 VAC	180 to 528 VAC	0.2 to 20 A (at 40°C)	0.2 to 4 A (at 40°C)				
G3NA-240B	24 to 240 VAC	19 to 264 VAC	0.1 to 40 A (at 40°C)	0.1 to 6 A (at 40°C)	440 A (60 Hz, 1 cycle)			
G3NA-440B	200 to 480 VAC	180 to 528 VAC	0.2 to 40 A (at 40°C)	0.2 to 6 A (at 40°C)				
G3NA-D210B	5 to 200 VDC	4 to 220 VDC	0.1 to 10 A (at 40°C)	0.1 to 4 A (at 40°C)	20 A (10 ms)			
G3NA-275B-UTU	24 to 240 VAC	19 to 264 VAC	1 to 75 A (at 40°C)	1 to 7 A (at 40°C)	800 A (60 Hz, 1 cycle)			
G3NA-475B-UTU	200 to 480 VAC	180 to 528 VAC	1 to 75 A (at 40°C)	1 to 7 A (at 40°C)	800 A (60 Hz, 1 cycle)			
G3NA-290B-UTU	24 to 240 VAC	19 to 264 VAC	1 to 90 A (at 40°C)	1 to 7 A (at 40°C)	1,000 A (60 Hz, 1 cycle)			
G3NA-490B-UTU	200 to 480 VAC	180 to 528 VAC	1 to 90 A (at 40°C)	1 to 7 A (at 40°C)	1,000 A (60 Hz, 1 cycle)			

Note: 1. The load current varies depending on the ambient temperature. Refer to Load Current vs. Ambient Temperature under Engineering Data.


2. When an OMRON Heat Sink (refer to *Options*) or a heat sink of the specified size is used.


■ Characteristics

Item	G3NA- 205B	G3NA- 210B	G3NA- 220B	G3NA- 240B	G3NA- 410B	G3NA- 420B	G3NA- 440B	G3NA- D210B	G3NA- 275B- UTU	G3NA- 290B- UTU	G3NA- 475B- UTU	G3NA- 490B- UTU
Operate time	1/2 of load power source cycle + 1 ms max. (DC input) 3/2 of load power source cycle + 1 ms max. (AC input)							1 ms 1/2 of load power source cycle + 1 ms max. (DC input) 3/2 of load power source cycle + 1 ms 3/2 of load power source cycle + 1 ms max. (AC input) max. (AC input)				
Release time	1/2 of load power source cycle + 1 ms max. (DC input) 3/2 of load power source cycle + 1 ms max. (AC input)							5 ms max. (DC input) 30 ms max. (AC input)	3/2 of load power source cycle + 1 ms max. (AC input)			
Output ON voltage drop	1.6 V (RMS) max.			- (-)		1.5 V max.	1.6 V (RM	S) max.	1.8 V (RM	S) max.		
Leakage current	5 mA max. (at 100 VAC) 10 mA max. (at 200 VAC)			20 mA max. (at 400 VAC) ma		5 mA max. (at 200 VDC)	5 mA max 100 VAC) 10 mA ma 200 VAC)		10 mA ma 100 VAC) 20 mA ma 200 VAC)	`		
Insulation resistance	100 MΩ m	nin. (at 500	VDC)									
Dielectric strength	2,500 VAC	C, 50/60 Hz	for 1 min						4,000 VAC, 50/60 Hz for 1 min			
Vibration resistance	Destructio	n: 10 to 55	to 10 Hz,	0.75-mm s	ingle ampli	tude (1.5-n	nm double	amplitude)				
Shock resistance	Destruction: 1,000 m/s ²											
Ambient temperature	Operating: -30°C to 80°C (with no icing or condensation) Storage: -30°C to 100°C (with no icing or condensation)											
Ambient humidity	Operating	: 45% to 8	5%									
Weight	Approx. 60	Эg		Approx. 70 g	Approx. 80	Эg		Approx. 70 g	Approx. 12	20 g		

Engineering Data

Load Current vs. Ambient Temperature






Note: The ambient operating temperature of the Y92B-P250NF is -30 to 70°C. Be sure the operating temperature is within this range.


One Cycle Surge Current: Non-repetitive

Note: Keep the inrush current to within the values shown by the dotted line if it occurs repetitively.




<u>Temperature</u> <u>Characteristics</u> (for Must <u>Operate Voltage</u> and Must <u>Release Voltage</u>)

G3NA-2 B AC input



Heat Sink Area vs. Load Current

G3NA-220B



Note: The heat sink area refers to the combined area of the sides of the heat sink that radiate heat. For example, when a current of 18 A is allowed to flow through the SSR at 40°C, the graph shows that the heat sink area is about 450 cm². Therefore, if the heat sink is square, one side of the heat sink must be 15 cm ($\sqrt{450}$ (cm²)/2) or longer.

Thermal Resistance Rth (Back of Junction SSR)

Model	Rth (°C/W)
G3NA-205B	3.22
G3NA-210B	2.62
G3NA-220B	1.99
G3NA-240B	0.45
G3NA-275B-UTU G3NA-475B-UTU G3NA-290B-UTU G3NA-490B-UTU	0.45
G3NA-D210B	2.62

Thermal Resistance Rth of Heat Sinks

Model	Rth (°C/W)
Y92B-N50	2.8
Y92B-N100	1.63
Y92B-N150	1.38
Y92B-A100	1.63
Y92B-A150N	1.37
Y92B-A250	1.00
Y92B-P250NF	0.46

Note: When using a commercially available heat sink, use one with a thermal resistance equal to or less that the OMRON Heat Sink.


Dimensions


Relays

Note: All units are in millimeters unless otherwise indicated.


G3NA-205B, G3NA-210B, G3NA-220B, G3NA-410B, G3NA-420B









Terminal Arrangement/ Internal Connections (Top View)




G3NA-240B, G3NA-440B







Terminal Arrangement/ Internal Connections (Top View)




Load power

supply

G3NA-D210B

Note: The load can be connected to either the positive or negative side. Four, M4 x 8 11.9 **Mounting Holes Terminal Arrangement/** dia. screws 4.5 Internal Connections (Top View) Two, 4.3-dia. or M4 holes Load 58 max. 47.5 44 Output 1 2 47.6±0.2 (–) 4 (+) Operating indicator 13.8 Input 4 5 25 max. 25 27 max. 43 max. Note: When connecting the load, either the positive or negative side of the load terminals can be connected.

G3NA-275B-UTU, G3NA-475B-UTU, G3NA-290B-UTU, G3NA-490B-UTU




■ Options (Order Separately)

One-touch Mounting Plate

The One-touch Mounting Plate is used to mount the GN3A to a DIN Track.

R99-12 FOR G3NA (for the G3NA and G3NE)




To mount the Relay to DIN Track, first mount it to the One-touch Mounting Plate and then attach it to the DIN Track as shown in the diagram. To remove the Relay from the DIN Track, pull down on the tab with a screwdriver in the direction of the arrow.

- When a Relay is mounted to DIN Track, use it within the rating for a Relay without a heat sink.
- Use the following DIN Tracks: PFP-100N or PFP-100N2.

Mounting Bracket

R99-11 (for the G3NA-240B, G3NA-440B)


Use Mounting Bracket R99-11 so that the G3NA-240B/-440B can be mounted with the same pitch as that of the G3N-240B.



Heat Sinks

Y92B-N50 Heat Sink (for the G3NA-205B, G3NA-210B, G3NA-D210B, G3NA-410B, G3NE-210T(L))


For surface mounting, a 30% derating of the load current is required (from the *Load Current vs. Ambient Temperature* graphs). The orientation indicated by the external dimensions is not the correct mounting orientation. When opening mounting holes, refer to the mounting hole dimensions.



Weight: approx. 400 g


Y92B-N100 Heat Sink (for the G3NA-220B, G3NA-420B, G3NE-220T(L))

For surface mounting, a 30% derating of the load current is required (from the *Load Current vs. Ambient Temperature* graphs). The orientation indicated by the external dimensions is not the correct mounting orientation. When opening mounting holes, refer to the mounting hole dimensions.




Y92B-N150 Heat Sink (for the G3NA-240B, G3NA-440B)


For surface mounting, a 30% derating of the load current is required (from the *Load Current vs. Ambient Temperature* graphs). The orientation indicated by the external dimensions is not the correct mounting orientation. When opening mounting holes, refer to the mounting hole dimensions.



Y92B-P250NF Heat Sink (for the G3NA-275B-UTU, G3NA-475B-UTU, G3NA-290B-UTU, G3NA-490B-UTU)

The orientation indicated by the external dimensions is not the correct mounting orientation. When opening mounting holes, refer to the mounting hole dimensions.





For surface mounting, a 30% derating of the load current is required (from the *Load Current vs. Ambient Temperature* graphs). The orientation indicated by the external dimensions is not the correct mounting orientation. When opening mounting holes, refer to the mounting hole dimensions.

Safety Precautions

—/!\Caution

Touching the charged section is likely to cause electric shock. Do not touch the G3NA terminal section (the charged section) when the power supply is ON. For G3NA models with terminal covers, be sure to attach the cover before use.



/!\ Caution

The G3NA and heat sink will be hot and are likely to cause burns. Do not touch the G3NA or the heat sink either while the power supply is ON, or immediately after the power is turned OFF.



/!\Caution


The internal snubber circuit is charged and will cause electric shock. Do not touch the G3NA's main circuit terminals immediately after the power is turned OFF.



Electric shock is likely to result. Be sure to conduct wiring with the power supply turned OFF. Always attach the terminal cover after completing wiring. Touching the terminals when they are charged is likely to cause electric shock.

/!\ Caution

The G3NA may occasionally explode. Do not apply a short-circuit to the load side of the G3NA. To protect against short-circuit accidents, install a protective device, such as a fuse or circuit breaker, on



Precautions for Safe Use

Although OMRON continuously strives to improve the quality and reliability of our relays, the G3NA contains semiconductors, which are generally prone to occasional malfunction and failure. Maintaining safety is particularly difficult if a relay is used outside of its ratings. Always use the G3NA within the rated values. When using the G3NA, always design the system to ensure safety and prevent human accidents, fires, and social damage even in the event of G3NA failure, including system redundancy, measures to prevent fires from spreading, and designs to prevent malfunction.

- 1. G3NA malfunction or fire damage may occasionally occur. Do not apply excessive voltage or current to the G3NA terminals.
- 2. Heat generated by a terminal error may occasionally result in fire damage. Do not operate if the screws on the output terminal are loose.
- 3. Heat generated from an G3NA error may occasionally cause the output element to short, or cause fire damage. Do not obstruct the airflow to the G3NA or heat sink.
- 4. Observe the precautions given in Precautions for Correct Use when wiring the G3NA and tightening screws. If the G3NA is used with improper wiring or insufficiently tightened screws, abnormal heat generation when the power is turned ON may result in burning.
- 5. Preventing Overheating

When using the High-capacity Heat Sink (Y92B-P250NF), always use a thermostat or other method to protect from overheating in the event that the fan stops.

6. Do Not Touch Fan Blades

When the fan is operating, do not touch the fan blades with any part of your body or allow foreign matter to come into contact with the blades. Always attach the enclosed finger guard when using the G3NA

Mounting

- Heat generated from an G3NA error may occasionally cause the output element to short, or cause fire damage. Do not obstruct the airflow
- · Be sure to prevent the ambient temperature from rising due to the heat radiation of the G3NA. If the G3NA is mounted inside a panel, install a fan so that the interior of the panel is fully ventilated.
- Mount the G3NA in the specified orientation. If the G3NA is mounted in any other orientation, abnormal heat generation may cause output elements to short or may cause burning.
- · Be sure that the G3NA clicks into place when mounting it to DIN Track. The G3NA may fall if it is not mounted correctly.
- Mount the DIN Track securely. The DIN Track may fall if improperly mounted.
- Do not mount the G3NA when your hands are oily or dirty, e.g., with metal powder. These may cause G3NA failure.
- Do not use the G3NA if the heat sink fins are bent, e.g., as the result of dropping the G3NA. Heat dissipation characteristics will be reduced, possibly causing G3NA failure.
- Apply a thin layer of Toshiba Silicone's YG6260 or Sinetsu Silicone's G746, or a similar product to the heat sink before mounting
- If a material with high thermal resistance, such as wood, is used, heat generated by the G3NA may occasionally cause fire or burning. When installing the G3NA directly into a control panel so that the panel can be used as a heat sink, use a panel material with low thermal resistance, such as aluminum or steel.
- · Use the specified heat sink or one with equivalent or better characteristics.
- Be sure the tightening torque of the G3NA is 0.78 to 0.98 N·m
- · Tighten the heat sink screws securely. Tightening torque: 0.98 to 1.47 N·m

Wiring

- · Abnormal heat generated by wires may occasionally result in fire damage. Use wires suitable for the load current.
- · Abnormal heat generated by terminals may occasionally result in fire damage. Do not operate if the screws on the output terminal are loose.

Tightening Torque

Screw size	Tightening torque
M4	1.2 to 1.47 N·m
M5	2.0 to 2.45 N·m

- Abnormal heat generated by terminals may occasionally result in fire damage. When tightening terminal screws, be sure that no non-conductive foreign matter is caught in screw.
- For GN3A Relays of 40 A or higher, use crimp terminals of an appropriate size for the wire diameter for M5 terminals.
- Do not use any wires with damaged sheaths. These may cause electric shock or leakage.
- Do not place wiring in the same conduit or duct as high-voltage lines. Induction may cause malfunction or damage.
- Use wires of an appropriate length, otherwise malfunction and damage may result due to induction.

Operating Conditions

- Only use the G3NA with loads that are within the rated values. Using the G3NA with loads outside the rated values may result in malfunction, damage, or burning.
- Use a power supply within the rated frequency range. Using a power supply outside the rated frequency range may result in malfunction, damage, or burning.



Operating and Storage Locations

Do not use or store the G3NA in the following locations. Doing so may result in damage, malfunction, or deterioration of performance characteristics.

• Do not use or store in locations subject to direct sunlight.

- Do not use in locations subject to ambient temperatures outside the range –20 to 60°C.
- Do not use in locations subject to relative humidity outside the range 45% to 85% or locations subject to condensation as the result of severe changes in temperature.
- Do not store in locations subject to ambient temperatures outside the range –30 to 70°C.
- Do not use or store in locations subject to corrosive or flammable gases.
- Do not use or store in locations subject to dust (especially iron dust) or salts.
- Do not use or store in locations subject to shock or vibration.
- Do not use or store in locations subject to exposure to water, oil, or chemicals.
- Do not use or store in locations subject to high temperatures or high humidity.
- Do not use or store in locations subject to salt damage.
- Do not use or store in locations subject to rain or water drops.

Precautions for Correct Use


Please observe the following precautions to prevent failure to operate, malfunction, or undesirable effect on product performance.

Before Actual Operation


- 1. The G3NA in operation may cause an unexpected accident. Therefore it is necessary to test the G3NA under the variety of conditions that are possible. As for the characteristics of the G3NA, it is necessary to consider differences in characteristics between individual SSRs.
- 2. Unless otherwise specified, the ratings in this catalog are tested values in a temperature range between 15°C and 30°C, a relative humidity range between 25% and 85%, and an atmospheric pressure range between 88 and 106 kPa (standard test conditions according to JIS C5442). It will be necessary to provide the above conditions as well as the load conditions if the user wants to confirm the ratings of specific G3NAs.

Mounting Method


SSR Mounting Pitch (Panel Mounting)







Ventilation Outside the Control Panel



If the air inlet or air outlet has a filter, clean the filter regularly to prevent it from clogging to ensure an efficient flow of air.

Do not locate any objects around the air inlet or air outlet, otherwise the objects may obstruct the proper ventilation of the control panel.

A heat exchanger, if used, should be located in front of the SSRs to ensure the efficiency of the heat exchanger.

- Please reduce the ambient temperature of SSRs. The rated load current of an SSR is measured at an ambient temperature of 25 or 40°C.
- An SSR uses a semiconductor in the output element. This causes the temperature inside the control panel to increase due to heating resulting from the passage of electrical current through the load. To restrict heating, attach a fan to the ventilation outlet or air inlet of the control panel to ventilate the panel. This will reduce the ambient temperature of the SSRs and thus increase reliability. (Generally, each 10 °C reduction in temperature will double the expected life.)

Load current (A)	5 A	10 A	20 A	40 A	75 A	90 A
Required number of fans per SSR	0.08	0.16	0.31	0.62	1.2	1.44

Example: For 10 SSRs with load currents of 10 A, 0.16 x 10 = 1.6

Thus, 2 fans would be required.


Size of fans: 92 mm², Air volume: 0.7 m³/min, Ambient temperature of control panel: 30 $^{\circ}$ C

If there are other instruments that generate heat in the control panel other than SSRs, additional ventilation will be required.

High-capacity Heat Sink (Y92B-P250NF)

DIN-track Mounting

- Assembled DIN Tracks are heavy. Mount the DIN Tracks securely. Be sure that the Heat Sink is securely locked to the DIN Track.
- Attach End Plates (PFP-M, order separately) to both ends of the Units on the DIN Track to hold them in place.
- To mount a Heat Sink to a DIN Track, press down at the point indicated by arrow 1 in the diagram and then press in the Heat Sink at the point indicated by arrow 2.




Applicable DIN Track

Mounting is possible on TE35-15Fe (IEC 60715) DIN tracks. DIN tracks from the following manufacturers can be used.


Manufacturer	Thickness: 1.5 mm	Thickness: 2.3 mm
Schneider	AM1-DE2000	
WAGO	210-114 or 210-197	210-118
PHOENIX	N35/15	N35/15/15-2.3

Direct Mounting

• Prepare mounting holes as shown in the diagram. Tightening torque: 0.98 to 1.47 N·m



• When mounting a Heat Sink directly, first remove the Fan Unit, then mount the Heat Sink by itself before attaching the Fan Unit again. (Remove the two screws shown in the following diagram.)



• First, temporarily mount the Heat Sink with the bottom two screws and then attach the top two screws with the mounting bracket sandwiched between the Heat Sink and mounting surface. Finally, tighten all four screws.

Ratings and Characteristics of High-capacity Heat Sink (Y92B-P250NF)

Fan Ratings

Rated voltage	200 V	
Operating voltage	85% to 110% of rated voltage	
Frequency	50/60 Hz	
Rated current (See note.)	0.085 A at 50 Hz 0.072 A at 60 Hz	
Rated speed (See note.)	2,500 r/min at 50 Hz 2,850 r/min at 60 Hz	

Note: Average values.

Thermostat Ratings

Operating temperature Approx. 90°C

Fan/Thermostat Characteristics

Insulation class	VDE: E (120°C)		
(Fan)	UL: A (105°C)		
	CSA: B (130°C)		
Insulation	100 MΩ min. (at 500 VDC) between power		
resistance	supply connections and non-charged metal		
	part		
Dielectric strength	Fan: 2,000 VAC for 1 min		
	Thermostat: 1,500 VAC for 1 min		
	Between power supply connections and		
	non-charged metal part		
	v 1		
Ambient operating	-30 to 70°C (with no icing)		
temperature			
Storage	-40 to 85°C (with no icing)		
temperature	、 3/		
Ambient operating	25% to 85%		
humidity			

- Use a commercial power supply (50/60 Hz) for the Fan.
- Be sure to turn OFF the power supply and wait for the blades to stop before inspecting the Fan.
- High-precision ball bearings are used in the fan and these may be damaged if the Fan is dropped or otherwise subjected to shock. The life and characteristics of the Fan will be reduced if the bearings are damaged. Do not subject the Fan to shock.
- The life of the Fan depends on the ambient temperature, As a guideline, the Fan life is 40,000 hours for continuous usage at 40°C.
- Be sure there are no objects near the air vents that would restrict air flow and no loose objects, such as electrical lines.
- The Fan is an OMRON R87F-A4A-93HP (200 VAC) Fan. Use the same model of Fan for replacement.
- The tightening torque of the mounting screw when replacing the Fan is 0.38 to 0.50 $\text{N}{\cdot}\text{m}.$
- Terminals equivalent to Faston #110 are used for the Fan power supply terminals.
- Refer to the following table for the OMRON Fan power supply plug cables (order separately).

Cable length	UL/CSA Conforming to Electrical Applian approved and Material Safety Law	
1 m	R87F-PC	R87F-PCJT
2 m	R87F-PC-20	R87F-PCJT-20

Preventing Overheating with a High-capacity Heat Sink (Y92B-P250NF)

- When the High-capacity Heat Sink is used, high-capacity switching at 75 A or 90 A requires forced cooling with a fan. Connect the Fan to a power supply according to its ratings specifications.
- If the Fan stops due to a power supply error, due to foreign matter in the power supply connection, or due to aging, the Heat Sink will heat to high temperatures, possibly resulting in failure of the SSR or adverse affects on other devices. Implement an overheating prevention measure, such as turning OFF the load current, if the Heat Sink overheats.
- A thermostat is provided to detect overheating. The thermostat uses a NC contact, i.e., the circuit will be opened for overheating. This thermostat can be used to stop the operation of the SSR. Implement an overheating prevention measure by using this signal to output an alarm or perform another response applicable to the system. Also, confirm that there is no problem with the overall system.
- Do not connect the thermostat directly to the load power supply. Connect it to a contactor or other shutoff device connected above the SSR.
- Terminals equivalent to Faston #187 are used for the thermostat terminals.

Ventilating a High-capacity Heat Sink (Y92B-P250NF)


• Refer to Ventilation Outside the Control Panel.

Operating Conditions

- Do not apply currents exceeding the rated current otherwise, the temperature of the G3NA may rise excessively.
- As protection against accidents due to short-circuiting, be sure to install protective devices, such as fuses and no-fuse breakers, on the power supply side.
- Do not apply overvoltages to the input circuit or output circuit. Failure or burning may result.
- Do not drop the G3NA or otherwise subject it to abnormal shock. Malfunction or failure may result.
- In spite of the repeated ON/OFF operation of the SSR, use it in continuous operation. This is to allow residual heat to dissipate after the SSR turns OFF. **??? meaning?**

Noise Terminal Voltage According to EN55011


The G3NA-UTU complies with EN55011 standards when a capacitor is connected to the load power supply as shown in the following circuit diagram.



Recommended Capacitor: 1 µF, 250 VAC **???okay as** is?


Loss Time

The loss time will increase when the G3NA is used at a low applied voltage or current. Be sure that this does not cause any problems.



Using DC Loads

For a DC or L load, a diode should be connected in parallel the load to absorb the counter electromotive force of the load.



<u>Fuses</u>

Connect a quick-break fuse in series with the load as a short-circuit protection measure. Use one of the fuses in the following table or one with equivalent or better characteristics.

Recommended Fuses

G3NA rated load current	Fuse model	Manufacturer	Applicable SSR
5 A	60LFF5	Kyosan Electric Manufacturing Com- pany	G3NA-205B
8 A	60LFF8		G3NA-210B
10 A	60LFF10		
15 A	60LFF15		G3NA-220B
20 A	60LFF20 50SHA20		
25 A	60PFF25 50SHA25		G3NA-240B
30 A	60PFF30 50SHA30		
40 A	50SHA40		
45 A	50SHA45		
50 A	50SHA50		G3NA-275B-UTU
75 A	50SHA75		
80 A	50SHA80		G3NA-290B-UTU
100 A	50SHB100		

Reverse Connection

The output terminal side of the G3NA-D210B is connected to a built-in diode to protect the SSR from damage that may result from reverse connection. The SSR, however, cannot withstand one minute or more if the wires are connected in reverse. Therefore, pay the utmost attention not to make polarity mistakes on the load side.

Precautions on Operating and Storage Environments

1. Operating Ambient Temperature

The rated value for the ambient operating temperature of the G3NA is for when there is no heat build-up. For this reason, under conditions where heat dissipation is not good due to poor ventilation, and where heat may build up easily, the actual temperature of the G3NA may exceed the rated value resulting in malfunction or burning.

When using the G3NA, design the system to allow heat dissipation sufficient to stay below the *Load Current vs. Ambient Temperature* characteristic curve. Note also that the ambient temperature of the G3NA may increase as a result of environmental conditions (e.g., climate or air-conditioning) and operating conditions (e.g., mounting in an airtight panel).

2. Transportation


When transporting the G3NA, observe the following points. Not doing so may result in damage, malfunction, or deterioration of performance characteristics.

- Do not drop the G3NA or subject it to severe vibration or shock.
- Do not transport the G3NA if it is wet.
- Do not transport the G3NA under high temperatures or humidity.
- Do not transport the G3NA without packing it properly.

Operation

1. Leakage Current

A leakage current flows through a snubber circuit in the G3NA even when there is no power input. Therefore, always turn OFF the power to the input or load and check that it is safe before replacing or wiring the G3NA.



3. Vibration and Shock

Do not subject the G3NA to excessive vibration or shock. Otherwise the G3NA may malfunction and internal components may be deformed or damaged, resulting in failure of the G3NA to operate.

To prevent the G3NA from abnormal vibration, do not install the G3NA in locations or by means that will subject it to vibration from other devices, such as motors.

4. Solvents

Do not allow the G3NA or the resin portion of the Fan's thermostat to come in contact with solvents, such as thinners or gasoline. Doing so will dissolve the markings on the G3NA.

<u>5. Oil</u>

Do not allow the G3NA terminal cover to come in contact with oil. Doing so will cause the cover to crack and become cloudy.

2. Screw Tightening Torque

Tighten the G3NA terminal screws properly. If the screws are not tight, the G3NA will be damaged by heat generated when the power is ON. Perform wiring using the specified tightening torque.

3. Handling Relays

Do not mount the G3NA when your hands are oily or dirty, e.g., with metal powder. These may cause G3NA failure.

4. Do Not Drop

Be careful not to drop a Relay or Heat Sink onto any part of your body while working. Injury may result. This is particularly true for the High-capacity Heat Sink (Y92B-P250NF), which weighs 2.5 kg.

ALL DIMENSIONS SHOWN ARE IN MILLIMETERS. To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

Cat. No. K067-E1-06?? In the interest of product improvement, specifications are subject to change without notice.

OMRON Corporation Industrial Automation Company

Industrial Devices and Components Division H.Q. Industrial Control Components Department Shiokoji Horikawa, Shimogyo-ku, Kyoto, 600-8530 Japan Tel: (81)75-344-7119/Fax: (81)75-344-7149

Printed in Japan 0204-?M